



## VALIDATED

---

- ZERO OZONE EMISSIONS - MEASURED OZONE EMISSIONS FROM APCO FAMILY DURING USE PHASE DOES NOT EXCEED 0.005 PPM AS TESTED BY UL 867

[UL.COM/ECV](http://UL.COM/ECV)

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180622-E336892  
**Report Reference** E336892-20180618  
**Issue Date** 2018-JUNE-22

**Issued to:** FILT AIR LTD  
1 Avshalom Road,  
P.O. Box 166  
3095101 Zikhron Yaaqov, ISRAEL


**This is to certify that representative samples of** Power Supplies, Electrostatic Air-cleaning Equipment - Component  
Component – High Voltage Power Supply/Ionizing type module Sterionizer D6.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 867, Standard for Safety for Electrostatic Air Cleaners.  
CSA Standard C22.2 No. 187, Electrostatic Air Cleaners.


**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





# ENVIRONMENTAL CLAIM VALIDATION SUMMARY

## FILT AIR LTD

### Sterionizer D6 Series

**Report Number:**

187806-4180

**Validation Period:**

12/14/2020 - 12/14/2021

---

**Claim:**

Zero Ozone Emissions – Measured Ozone Emissions from Sterionizer™ D6 Series during use phase does not exceed 0.005 ppm as tested by UL 867.

**Method:**

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

**Facility:**

Filt Air Ltd.